



Inspection Checklist Internal Plumbing

Permit # _____ Map ___ Lot ___ Date of Rough-In Plumbing __/__/__
Date of Final Inspection __/__/__

Drain and Vent Rough-In:

- P traps and back venting or Section 13
- Drain piping and fittings are of proper materials and labeled. Table 3.5
- Drain piping is sized properly. Table 5.1 and 5.3 Kitchen sink and clothes washer is 2 inches.
- Clean outs are of proper type and location. Section 5 (F)
- Vents are proper material, size and location. Load Table 5.1; Size, Table 5.3; Section 8 (If using Section 13 note difference)
- Piping is secured at proper interval and with proper material. Section 4 (N)
- Drain pipe pitch is proper, Sections 5 (G) See at Final
- Fittings are of the proper type and use. Section 4 (J)
- Proper primer and cement or other connections are used. Section 9
- Bathroom exhaust vent termination and location is correct Section 14
- Nail plates installed where needed
- Pressure test is successful Section 4

Water Supply Rough-In

- Proper piping is used and stamped or labeled. Table 3-5
- Water piping is properly sized. Table 11-2
- Water piping is properly secured, type and location. Section 4 (N)
- Joints and fittings are of the proper type and joined properly. Section 9 (B) And Table 9-1
- Lead free solder is used
- Pressure test for water distribution is successful Section 11 (H)

Comments, Conditions, or Corrections

- Water is heated and stored in a tank
- Tank is properly located within the building. Section 4 and 11
- Pressure and temperature relief valves are properly located and installed on the tank Section 11 (G), 3
- Vacuum breakers are proper Section 11 (G)
- Shut off valves are of a proper type and location. Section 11 (E)
See also Section 11 Figure 11-2
- Water is heated in a tankless coil
- Mixing valves and pressure relief valves are properly located and installed.
Section 11 (G), Figure 11-2

Final Plumbing Inspection

- Fixtures are properly secured and caulked Section 10
- Backflow prevention is installed Section 11 (C)
- Shut offs are in place where required Section 11 (E)
- Traps are of the proper type and location Section 13 or Section 8
- Water is of a proper pressure Section 11 (G)
- Water is of a proper temperature Section 11 (G)
- There are no leaks
- Dishwasher and waste installed correctly, either air gap or indirect
Section 7 (H)
- Toilets flush properly
- Rooms with water closets and similar fixtures have proper ventilation, outside window or 30 cubic feet per minute evacuation fan.
- Vent pipe exhaust are proper location Section 14
- Clothes washer standpipe is installed at the proper location, height, and length
Section 7 (D)
- Traps are of proper type and location
- Distances between vents and traps are proper (Table 8-1)
- Hose bibs and other similar connectors have back flow prevention
Section 11 (B), (C)
- Applicants copy of permit is on site for LPI's signature
- Towns copy signed and filed with a copy of this checklist.

Comments or Conditions

Licensed Plumbing Inspector

